SHERIDAN WYOMING VAMC

1898 FORT ROAD; BUILDING 42 SHERIDAN, WYOMING PROJECT #666-310 E85 FUELING STATION



INDEX:

CG101 COVERSHE

P101 GRADING PLAN AND SITE PLAN
U501 UST DETAILS AND HOLD DOWN

E101 ELECTRICAL PLAN AND NOTES


VEEDER ROOT OVERFILL ALARM
UST DETAILS


M102 UST DETAILS


FINALIZED DESIGN DEVELOPMENT - FOR CONSTRUCTION

Drawing Title
COVERSHEET Project Title
E85 FUELING STATION ARCHITECT/ENGINEERS: CONSULTANTS: Office of Construction Building Number Aegis Engineering, Inc. and Facilities A Veteran Owned Small Business Approved: Project Director Drawing Number Management 10940 South Parker Road Ste: 199 Parker, Colorado VAMC SHERIDAN CG101 Checked VAPAHCS PLANNING AND ENGINEERING || 10 OCT 13 HALL Dwg.1 of 9


 2
 5








2 4 5





BUOYANCY CALCULATION (5,000 GAL. TANK) CALCULATION BASED ON SUBMERGED WEIGHT OF MATERIALS (WATER TABLE AT

GRADE): TANK WITH SPHERICAL ENDS, 6.33' O.A. (6' NOMINAL) TANK LENGTH 26'-5" TANK DIAMETER 6'-0"

TRY (2) 12'-0" DEADMAN, EACH SIDE, 12" WIDE x 12" HIGH

EMPTY TANK UPLIFT = 5,000 GAL = 668 CU FT

7.48 GAL/CF 668 CU FT x 62.4 LBS/CF = 41,683 LBS (DISPLACED WATER)

TANK SUMP UPLIFT = (2) x 3.14 x 1.75² x 4' = 77 CU FT 77 CU FT x 62.4 LBS/CF = 4,805 LBS (DISPLACED WATER)

TOTAL TANK UPLIFT = 41,683 LBS + 4,805 LBS = <u>46,488 LBS</u>

TANK SLAB: .67' x 26' x 8' = 139.4 CU FT 174.2 CU FT x 150 LBS/CF = 20,895 LBS

2 BACKFILL ABOVE TANK: 4' x 6' x 26' = 624 CU FT - 77 CU FT (SUMP) = 547 CU FT

547 CU FT x 110 LBS/CF = 60,170 LBS

3 CURVED BACKFILL ABOVE TANK: 3.14 x 3'2 x 26' = 735 CU FT

6' x 6' x 26' = 936 CU FT 936 CU FT - 735 CU FT = <u>201 CU FT</u> = 101 CU FT


101 CU FT x 110 LBS/CF = $\underline{11,110 LBS}$ 4 GRAVEL ABOVE DEADMEN:


12" x 11' x 24' x 2 = 528 CU FT 528 CU FT x 110 LBS/CF = 58,080 LBS

5 CONCRETE DEADMEN: 1' x 1' x 24' = 24 CU FT

24 CU FT x 150 LBS/CF x 2 = 3,600 LBS 6 DRY WEIGHT OF TANK:

> TOTAL HOLD DOWN: 156,855 LBS = 3.4 F.S.








- ALL FLANGED NOZZLES ARE AXIALLY MOUNTED ON THE TANK TOP CENTERLINE.

- ALL NPT FITTINGS MUST BE POSITIONED ON THE TOP CENTERLINE OF THE TANK. - AVAILABLE IN 2", 4" AND 6" SIZES.

			NOZZLE	SIZES)	
	NOZZLE	# OF	CIRCLE	HOLE	FLANGE	PROJECT
	DIA	BOLTS	DIA.	DIA.	DIA.	HGT.
	2"	4	4 3/4"	3/4"	6"	6"
	4"	8	7 1/2"	3/4"	9"	6"
	6"	8	9 1/2"	7/8"	11"	6"
	8"	8	11 3/4"	7/8"	13 1/2"	6"
NON	10"	12	14 1/4"	1"	16"	6"
U.L.	12"	12	17"	1"	19"	6"
O.L.	14"	12	18 3/4"	1 1/8"	21"	6"









FINALIZED DESIGN DEVELOPMENT - FOR CONSTRUCTION

Drawing Title
UST DETAILS AND HOLD DOWN ARCHITECT/ENGINEERS: CONSULTANTS: Office of E85 FUELING STATION 666-310 Construction Aegis Engineering, Inc. and Facilities A Veteran Owned Small Business Approved: Project Director Drawing Number Management 10940 South Parker Road Ste: 199 Parker, Colorado SHERIDAN ، 08OCT13 CU501 VAPAHCS PLANNING AND ENGINEERING 10 OCT 13 Dwg. 3 of 9





PARTIAL ONE LINE DIAGRAM (NO NEW WORK) NO SCALE BEFORE PERFORMING ANY WORK E.C. TO VERIFY THE EXISTING CONDITIONS OF THE ELECTRICAL SERVICE. VERIFY EXISTING FAULT CURRENT CALCULATION AT XFMR IS A MAXIMUM OF 10,000 ISCA. TRANSFORMER EXISTING GROUNDING (4-3/0 THWN CU)2-1/2°C. (4-3/0 THWN CU)2-1/2°C. EXISTING FUELING STATION IS BEING REMOVED AND REPLACED. NO CHANGE IN LOAD ON PANEL 42-1P1.

	FAULT CURRENT TABLE	
FAULT	CURRENT SOURCE, CONDUCTOR IMPEDANCE	AVALIABLE SYM. FAULT CURRENT
1.	FAULT AT XFMR	10,000 ISCA
2.	20' 3/0 CU	8,930 ISCA

		E	QUIP	MENT	Γ SCHEDULE				
PLAN CODE	DESCRIPTION	VOLTS	PHASE	LOAD (WATTS)	WIRE SIZE	DISC. TYPE	DISC. SIZE	FUSE SIZE	FURN
DISP	DISPENSER	120	1	1000	(2-#12 THWN CU, #12G)1/2"C.	FSW			MANU.
PUMP	FUEL PUMP	208	1	1580	(2-#12 THWN CU, #12G)1/2"C.	FSW			MANU.
CARD	CARD READER	120	1	360	(2-#12 THWN CU, #12G)1/2"C.	FSW			MANU.


FSW = FUSED SAFETY SWITCH; CB = CIRCUIT BREAKER; RECP = RECEPTACLE; SW = SWITCH/OCCUPANCY SENSOR; E.C. TO VERIFY THE NAMEPLATE DATA ON THE ACTUAL EQUIPMENT PROVIDED BEFORE DOING ANY WORK.

	LIGHTI	NG F	IXTURE S	CHEDULE		
PLAN CODE	DESCRIPTION	VOLTS	MANUFACTURE	CATALOG #	LAMP TYPE	TOTAL WATTS
Α	CANOPY LIGHT	MVOLT	LITHONIA	DSXSC-LED30C- 1000-50K-T5EMVOLT	LED	107

FIXTURES F3, F3-EM, HB, HB-EM TO HAVE MULTIPLE BALLASTS FOR INBOARD/OUTBOARD SWITCHING.


E.C. TO VERIFY FIXTURE TYPES, SWITCHING, AND LOCATIONS WITH ARCHITECT.


CIVIL ENGINEER IS DESIGNING POLE BASES FOR 100 MPH.




	SHEET NOTES
1>-	SEALS REQUIRED AT ALL CONDUITS LEAVING PANEL(NEC 514).
<2>-	SEALS REQUIRED AT ALL GAS PIPE DESPENSORS(NEC 514).
<u>3</u> -	SEALS REQUIRED AT CONDUITS LEAVING CLASS I HAZARDOUS LOCATION(NEC 514). E.C. TO USE EQUIPMENT AND WIRING RATED FOR CLASS 1 LOCATIONS.
<u>4</u> >-	CLASS I HAZARDOUS LOCATION. E.C. TO USE EQUIPMENT AND WIRING METHODS RATED FOR CLASS I LOCATIONS. THREADED RIGID METAL CONDUIT OR THREADED STEEL INTERMEDIATE METAL CONDUIT.
<5>-	LOCATION OF SECURITY EQUIPMENT. E.C. TO PROVIDE 3/4"C AND PULLSTRING BACK TO COMM. ROOM. VERIFY EXACT LOCATION OF EQUIPMENT WITH I.T.

6 - E.C. TO PROVIDE 3/4"C. AND PULLSTRING BACK TO TLS.








CONTRACTOR COORDINATION SCHEDULE						
ITEM FURNISHED	FURNISHED BY	MOUNTED BY	WIRED BY			
LOCATING EXISTING EXTERIOR UTILITIES	G.C.	-	-			
LOCATING EXISTING INTERIOR UTILITIES	P.C./E.C.	-	-			
CONCRETE EQUIPMENT PADS	G.C.	G.C./S.C./M.C.	-			
EXCAVATION, BACKFILL, AND CONCRETE OR ASPHALT PAVING FOR UTILITIES OR OTHER M/E EQUIPMENT.	G.C.	AHJ/G.C./C.C.	-			
FLASHING OVER THE TOP OF PLATFORMS AND CURBS	G.C.	G.C./R.C.	-			
ROOFING REPAIR AND/OR SEALING OF ROOFING SYSTEM	G.C.	G.C./R.C.	-			
MOTOR STARTERS AND COMBINATION MOTOR STARTERS TO INCLUDE THERMAL OVERLOADS.	M.C./P.C.	E.C.	E.C.			
STARTERS IN MOTOR CONTROL CENTERS	M.C.	E.C.	E.C.			
MULTISPEED SWITCHES.	M.C.	M.C.	E.C.			
DISCONNECT SWITCHES.	E.C.	E.C.	E.C.			
CONDUIT FOR ALL WIRING.	E.C.	E.C.	-			
CONTROL TRANSFORMERS FOR HVAC EQUIPMENT	M.C.	M.C.	E.C.			
HVAC CONTROL WIRING 48 VOLTS AND LESS.	T.C./M.C.	T.C./M.C.	T.C./M.C.			
WIRING GREATER THAN 120 VOLTS.	E.C.	E.C.	E.C.			
INTERLOCK	M.C./E.C.	E.C.	E.C.			
NON-LOAD VOLTAGE CONTROL SYSTEMS	M.C.	M.C.	M.C.			
DUCT AND SMOKE DETECTORS INTERFACED WITH BUILDING FIRE ALARM SYSTEM.	F.A.C/E.C.	M.C.	F.A.C/E.C.			
FIRE PROTECTION CONTROLS INCLUDING FLOW SWITCHES	M.C.	M.C.	MC./E.C.			

FINALIZED DESIGN DEVELOPMENT - FOR CONSTRUCTION



 2
 5

